



TYP ROAD SECTION

TYP SLOPE SECTION

1. HALL ROAD SHALL BE 2'-1/2" A.C. BASE CRUSHED ROCK 12" TO 18" THICK PLACED IN 6" LIFTS, TYPICAL, AND COMPACTED TO 98% C.A. ROAD SHALL MAINTAIN A 2% CROSS-SLOPE.
2. MINIMUM COVER DEEP 15", 18", OR 24" C.P.P. SHALL BE 12" OF A.C. BASE CRUSHED ROCK.
3. CONTRACTOR SHALL INSTALL 2'-4"5" BENJIS AFTER FES TO FOLLOW LAYOUT OF POET AROUND HALL ROAD WHILE MAINTAINING THE MINIMUM COVER OVER C.P.P.

THE CONTRACTOR SHALL POTHOLE ALONG ALL ASPHALT OR PAVEMENT AREAS TO REPAIR CRACKS OR IF NEW CELL LOCATIONS WERE GRADING OR EXCAVATION OPERATIONS WERE OCCUR TO VERIFY LAYER DEEP PRIOR TO ANY CONSTRUCTION OPERATIONS.

FINAL CONSTRUCTION PLANS